



FILM LOCATION CHECKLIST

PERMIT #:	DATE OF FILMING:	PHONE NO.:	FSO:
ADDRESS	CITY	STATE	ZIP CODE
CONTACT NAME:	CONTACT TITLE:	LOCATION OPEN TO THE PUBLIC: <input type="checkbox"/>	LOCATION CLOSED TO THE PUBLIC: <input type="checkbox"/>

CORRECTIVE ACTION TAKEN?		Y = Yes	N = No	NA = Not Applicable
I.	<u>PERMITS:</u>			
	[] Film Permit			
	[] Tent Permit			
	[] Special Effects (Pyrotechnic) Permit			
	[] Refueller Vehicle			
	[] Welding and/or cutting			
II.	<u>ACCESS:</u>			
	[] Fire Truck access must be maintained (20 feet wide).			
	[] Fire hydrants, extinguishers, sprinkler and standpipe connections clear of all equipment and vehicles.			
III.	<u>EXITING:</u>			
	[] All designated fire, emergency and regular exits must be clear and maintained around set.			
	[] Above exits must be adequate, visible, and well marked.			
	[] All exits must be clear of hazards (flammable liquids, LPG & pyrotechnics, etc.).			
IV.	<u>FLAMMABLE LIQUIDS AND GAS:</u>			
	[] Proper storage of flammable liquids in approved containers (max. v 5 gal./container).			
	[] Propane and other pressure vessels secured and stored outside with "NO SMOKING" and "NO WELDING" signs.			
	[] Approved hoses and valves for pressurized gasses.			
	[] Flammable liquids and gasses kept away from heat sources.			
	[] No refueling of generators or other equipment while in operation.			
	[] Refueling done in approved areas.			
	[] Refueller vehicle must have proper permits.			
	[] Supply and receiving vessels bonded together.			
	[] Spray painting and lacquer application approved and performed safely.			
	[] Proper ventilation to prevent flammable vapors from accumulating.			
V.	<u>ELECTRICAL AND LIGHTING:</u>			
	[] Chords and connectors of an approved type.			
	[] No distribution boxes or spiders within a 4 foot perimeter (unless approved by BFD).			
	[] A/C equipment properly grounded.			
	[] Generators inspected and placed in approved locations.			
	[] Generators grounded or insulated.			
	[] Cables properly protected, dressed and kept as clear as possible of exits.			
	[] Lighting adequately separated from combustible materials/surfaces.			
	[] Electrical panel hook-up with permit from Building and Safety.			
	[] Maintain 3 foot clearance around all electrical panels.			
VI.	<u>SMOKING:</u>			
	[] Smoking prohibited near pyrotechnic/special effects, flame, liquid storage and display areas.			
	[] Smoking areas designated, clearly marked with butt cans.			
	[] "NO SMOKING" signs prominently visible where smoking is prohibited.			
VII.	<u>PYROTECHNIC:</u>			
	[] Proper license in possession of pyro technician.			
	[] Bakersfield Fire Department Special Effects Permit on site.			
	[] Fire Department briefed on proposed activity.			
	[] Fire extinguisher provided by pyro technician.			
	[] Fire extinguisher charged and in good working order.			
	[] Special effects used as per Bakersfield Fire Department Special Effects Permit.			

